



LAYC Career Academy PCS - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
LAYC Career Academy PCS	WS-010-001	Food Prep Sink	Basement	In kitchen B06			WF-012025-010001-08	6/17/2025	FT-FY25-012025-010001-A	<1	FT-FY25-012025-010001-B	3.37
LAYC Career Academy PCS	WS-010-002	Break Room	2	In kitchenette adjacent to room 215			WF-012025-010002-07	6/17/2025	FT-FY25-012025-010002-A	<1	FT-FY25-012025-010002-B	<1
LAYC Career Academy PCS	WS-010-003	Break Room	3	In kitchenette adjacent to room 314			WF-012025-010003-07	6/17/2025	FT-FY25-012025-010003-A	<1	FT-FY25-012025-010003-B	<1
LAYC Career Academy PCS	WS-010-004	Break Room	4	In kitchenette adjacent to room 402			WF-012025-010004-07	6/17/2025	FT-FY25-012025-010004-A	<1	FT-FY25-012025-010004-B	<1
LAYC Career Academy PCS	WS-010-005	Cooler	1	In hallway across from elevator	High	Left	WF-012025-010005-07	6/17/2025	FT-FY25-012025-010005-A	<1	FT-FY25-012025-010005-B	<1
LAYC Career Academy PCS	WS-010-006	Cooler	1	In hallway across from elevator	Low	Right	WF-012025-010006-07	6/17/2025	FT-FY25-012025-010006-A	<1	FT-FY25-012025-010006-B	<1
LAYC Career Academy PCS	WS-010-007	Bottle Filler	1	In hallway across from the elevator			WF-012025-010007-05	6/17/2025	FT-FY25-012025-010007-A	<1	FT-FY25-012025-010007-B	<1
LAYC Career Academy PCS	WS-010-008	Bottle Filler	2	In kitchenette adjacent to room 215		Right	WF-012025-010008-03	6/17/2025	FT-FY25-012025-010008-A	<1	FT-FY25-012025-010008-B	<1