



LAYC Career Academy PCS - Lead in Water Test Results



FY26 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
LAYC Career Academy PCS	WS-164-001	Break Room	3	In room 359			WF-082026-164001-01	7/6/26	WF-082026-164001-01-A	<1	WF-082026-164001-01-B	<1
LAYC Career Academy PCS	WS-164-002	Bottle Filler	3	In hallway adjacent to room 358			WF-082026-164002-01	7/7/26	WF-082026-164002-01-A	<1	WF-082026-164002-01-B	<1
LAYC Career Academy PCS	WS-164-003	Cooler	3	In hallway adjacent to room 358	Left		WF-082026-164003-01	7/8/26	WF-082026-164003-01-A	<1	WF-082026-164003-01-B	<1
LAYC Career Academy PCS	WS-164-004	Cooler	3	In hallway adjacent to room 358	Right		WF-082026-164004-01	7/9/26	WF-082026-164004-01-A	<1	WF-082026-164004-01-B	<1
LAYC Career Academy PCS	WS-164-005	Bottle Filler	3	In between restrooms			WF-082026-164005-01	7/10/26	WF-082026-164005-01-A	<1	WF-082026-164005-01-B	<1
LAYC Career Academy PCS	WS-164-006	Cooler	3	In between restrooms	Left		WF-082026-164006-01	7/11/26	WF-082026-164006-01-A	<1	WF-082026-164006-01-B	<1
LAYC Career Academy PCS	WS-164-007	Cooler	3	In between restrooms			WF-082026-164007-01	7/12/26	WF-082026-164007-01-A	<1	WF-082026-164007-01-B	<1
LAYC Career Academy PCS	WS-164-008	Break Room	3	In warming pantry			WF-082026-164008-01	7/13/26	WF-082026-164008-01-A	<1	WF-082026-164008-01-B	<1
LAYC Career Academy PCS	WS-164-009	Bottle Filler	3	In hallway opposite 328			WF-082026-164009-01	7/14/26	WF-082026-164009-01-A	<1	WF-082026-164009-01-B	<1
LAYC Career Academy PCS	WS-164-010	Cooler	3	In hallway opposite 328	Left		WF-082026-164010-01	7/15/26	WF-082026-164010-01-A	<1	WF-082026-164010-01-B	<1
LAYC Career Academy PCS	WS-164-011	Cooler	3	In hallway opposite 328	Right		WF-082026-164011-01	7/16/26	WF-082026-164011-01-A	<1	WF-082026-164011-01-B	<1
LAYC Career Academy PCS	WS-164-012	Break Room	3	In staff lounge			WF-082026-164012-01	7/17/26	WF-082026-164012-01-A	<1	WF-082026-164012-01-B	<1